

ENERGY AUDIT REPORT



CHRISTIAN COLLEGE
Kattakada

(Affiliated to the University of Kerala)



House No.3, H street Jawahar Nagar, Kowdiar P O
Thiruvananthapuram 695 003
Kerala, India

PH: +91 94972 55554 / +91 94963 55554

www.vydyuthi.com

APRIL 2021


ACKNOWLEDGMENT

We, hereby express sincere thanks and gratitude to Dr. N.Selvaraj, Secretary & Chief Administrator and Dr. N.S. Vincent Joy, Principal of the Christian College, Kattakkada, Thiruvananthapuram, for the whole hearted support, extended for the Energy Audit. Also, sincere thanks to Prof. L.S. Paul Raj, Vice Principal, and Dr. L.D. Afinisha Deepam, IQAC Co Ordinator, for their co- operation and the needful assistance, extended to us, during the conduct of the Energy Audit.

The Society for Higher Education, South Kerala Diocese (SIUC) has entrusted **M/s. Indira Babu Energy Ventures Pvt. Ltd, (Vydyuthi Energy Services)**, the work of conducting an Energy Audit, at the Christian College, Kattakkada, Thiruvananthapuram.

The Energy Audit was carried out by the following qualified and experienced energy auditors/professionals of Vydyuthi Energy Services.

1. Er. Sudha Kumari. R (BEE Certified Energy Auditor), Head of Energy Efficiency
2. Dr. Vani Vijay, Technology & Research expert
3. Er. Kokila Vijayakumar, Operations & Data analytics consultant
4. Er. Akhil Dev D J, Energy & Market Analyst



Managing Director
Indira Babu Energy Ventures Pvt. Ltd.
(Vydyuthi Energy Services)

Thiruvananthapuram

14-04-2021

Vydyuthi Energy Services (VES)

Vydyuthi Energy Services (VES) under Indira Babu Energy Ventures Pvt. Ltd, located in Kerala, India with services focused on energy sector. VES helps businesses and organizations across sectors to identify energy efficiency drivers and enable them to adopt viable action plans.

VES is empaneled as Energy Auditing Firm under Energy Management Centre Government of Kerala with Empanelment No: EMCEEA-4720E

VES works with the vision of supporting the economy in achieving the Sustainable Development Goals (SDG) target by 2030. The important focus of the activities are to Enhance awareness, acceptability and applicability of energy efficiency and renewable energy technologies and provide energy services to build a sustainable future for generations to come Other than energy auditing, VES offers consulting, training, project management services and R&D in the below areas for businesses in India and abroad

- Energy Efficiency
- Renewable Energy
- Power Quality assessment
- E-Mobility
- Carbon Accounting.



Contents

1. Executive Summary	5
2. Introduction	7
3. Connected Load Description	8
4. Energy Performance Analysis	11
5. Energy Saving Potential	11
6. Recommendations for Energy Saving	15
7. Details of energy savings calculations	16
(a). Consumer No.1145529000140, Connected load 36kW	16
(b). Consumer No.1145523000141, Connected load 10kW	18
8. Annexures	20
8.1. Annexure 1. Energy Audit Sheets (enclosed).....	20
8.2. Annexure 2. Electricity Bill Details (Bills enclosed).....	21

1. Executive Summary

The objective of this Energy Audit and Report is to evaluate the current energy efficiency and prospective energy saving potential of the College - **Christian College, Kattakkada, Thiruvananthapuram**, to achieve greater energy efficiency and reduce energy consumption, while maintaining current level of occupant's comfort. Indira Babu Energy Ventures Pvt. Ltd (Vydyuthi Energy Services), conducted the Energy Audit in the College on 8th & 9th April 2021.

The **Christian College, Kattakkada, Thiruvananthapuram**, is under the Electrical section, Kattakkada of Electrical Division Kattakkada, with **Consumer Nos.1145529000140**(Science Block, Auditorium etc.,Connected load 36kW, LT-6A, three phase with average monthly energy consumption of 1673kWh) & **1145523000141**(Administrative Block, Arts Block, Central Library Building etc., Connected load 10kW, LT-6A, Three phase with average monthly energy consumption of 2624kWh.)

The details of the Energy Audit with calculations and energy saving potential together with cost-benefit analysis are included in this report. The report finds prospects in improved energy efficiency of the College.

It is observed an **Energy saving potential of about 6617kWh per year, for Consumer No.1145529000140**, resulting approximate annual financial savings of **Rs.37719**.

&

Energy saving potential of about 6805kWh per year for Consumer no. 1145523000141, resulting approximate annual financial savings of **Rs.44234**.

**Table 1.a. Retrofitting in Buildings – Science Block, Auditorium etc.
(Consumer no.1145529000140, Connected load- 36kW)**

SI No	Description of work	Rate per item (Rs.)	No. of items required (Nos)	Investment Required (Rs.)	Annual Energy Saving Potential (kWh)	Annual Financial Savings (Rs.)	Pay back Period in Years
1	Retrofitting T12 Fluorescent Tube lights with 18W LED Tube light	400	25	10000	374	2132	4.6
3	Retrofitting T8 Fluorescent Tube lights with 18W LED Tube light	400	125	50000	990	5643	8.8
4	Retrofitting Compact Fluorescent Lamp(CFL) with 7w LED bulb	160	10	1600	69	395	4
5	Retrofitting old inefficient ceiling fan with BEE star rated ceiling fan with service value 4.0 or above	2100	145	304500	5184	29549	10
Total				366100	6617	37719	6.8

Energy saving potential of about 6617kWh per year, with an annual financial savings of Rs. 37719(approx.) . Investment required is about Rs. 366100.

Table 1.b. Retrofitting in Buildings – Administrative Block, Arts Block, Central Library Building etc.(Consumer no.1145523000141,connected load-10kW)

SI No	Description of work	Rate per item (Rs.)	No. of items required (Nos)	Investment Required (Rs.)	Annual Energy Saving Potential (kWh)	Annual Financial Savings (Rs.)	Pay back Period in Years
1	Retrofitting T12 Fluorescent Tube lights with 18W LED Tube light	400	7	2800	209	1359	2
3	Retrofitting T8 Fluorescent Tube lights with 18W LED Tube light	400	135	54000	2138	13897	3.8
4	Retrofitting Compact Fluorescent Lamp(CFL) with 7w LED bulb	160	4	640	25	163	4
5	Retrofitting old inefficient ceiling fan with BEE star rated ceiling fan with service value 4.0 or above	2100	124	260400	4433	28815	9
Total				317840	6805	44234	4.7

Energy saving potential of about 6805kWh per year, with an annual financial savings of Rs.44234(approx.) . Investment required is about Rs.317840.

2. Introduction

The **Christian College, Kattakkada, Thiruvananthapuram**, functions in various buildings. This College was established in 1965 and is an Arts and Science College, under the Society for Education of the SIUC community of the Church of South India and registered under the Travancore-Cochin Literary, Scientific and Charitable Societies Registration Act XII of 1955 and is affiliated to the University of Kerala and recognized by the University Grants Commission.

The major sections in the College, include Administrative Block, Arts Block, Science Block, Auditorium, Central Library Building etc.

Data regarding connected loads and usage pattern, were identified during the Energy Audit and preliminary survey on 8th & 9th April 2021. Below image shows the building, where Audit was carried out.



Image 2.1: Christian College, Kattakkada Building front view

3. Connected Load Description

The various buildings have major loads, which include Lights, Fans, computers, Air Conditioner, water pump etc, and office use appliances.

Most of the Lights used are T12/T8 Fluorescent Tube lights, which are not energy efficient. LED & CFL lights are rarely used, which are comparatively energy efficient. Fans used are of ordinary inefficient type and most of the fan regulators are ordinary inefficient type. Electronic fan regulators are rarely used, which are energy efficient.

Air conditioners are BEE Star labelled, which are energy efficient, and Air conditioned rooms are not, properly, air tight, viz, Ground Floor AC room of Administrative Block.

Computers used are of energy efficient models.

The total connected load is 36kW for **Consumer No.1145529000140** (Science Block, Auditorium etc.) and 10kW for **Consumer no.1145523000141** (Administrative Block, Arts Block, Central Library Building etc.), as per utility Electricity bill. However, the sum of connected load accounts to approximately 37.5Kw for **Consumer No.1145529000140** and 24kW for consumer no.**1145523000141**, as per the available data collected during the energy audit. This increase in connected load needs to be regularised at the concerned Electricity Office.

The details of each appliance, in terms of location and numbers are provided in Annexure 1 of this document.



Image 3.1: Energy Efficient LED Tube light and Electronic type Fan regulator



Image 3.2: Old Inefficient type Tube light and Resistor type Fan regulator

The load pattern observed are as shown in tables 2.a and 2.b respectively, according to the available data, during the energy audit. The load details, with number of each appliance, are shown in annexure 1. The contribution of each appliance to total connected load is shown in images 4.a and 4.b, for the buildings, respectively.

Table 3.a : Load Distribution
(Consumer No. 1145529000140)

Loads	Total Wattage (W)	Percentage of load (%)
T12 & T8 Tube lights	5800	15
CFL & LED lighting	1525	4
Ventilation (Fan)	12125	32
Air conditioner	6300	17
Computer and peripherals	1440	4
Pump	5968	16
Other appliances	4522	12
TOTAL	37500	100.00%

Image 3.a. Load Distribution chart
Consumer No. 1145529000140





Table 3.b: Load Distribution
(Consumer No. 1145523000141)

Loads	Total Wattage (W)	Percentage of load (%)
T12 & T8 Tube lights	5098	22
CFL & LED lighting	515	2
Ventilation(Fan)	9390	39
Air conditioner	3200	13
Computer and peripherals	5000	21
Other Appliances	800	3
TOTAL	24165	100.00%

Image 3.b. Load Distribution chart
(Consumer No. 1145523000141)



4. Energy Performance Analysis

The details, calculated approximate annual energy consumption of various loads, are shown in tables 3.a and 3.b. From the pie charts in images 5.a and 5.b, it can be seen that major energy consumption are by Ventilation (Fan), Lighting, Air conditioning and computers.

Most of the existing lights are inefficient T12 & T8 fluorescent tube lights and these can be replaced with LED lights. The fans used are of ordinary inefficient types and these can be retrofitted with BEE Star labelled fans. The calculations are given in Section 7.

Table 4.a.: Annual energy consumption- Equipment wise (Consumer No. 1145529000140)

Loads	Annual energy consumption (kWh)	Percentage of annual energy consumption (%)
T12 & T8 Tube lights	2552	13
CFL & LED lighting	201	1
Ventilation (Fan)	15551	79
Air Conditioner	176	1
Computer and peripherals	120.648	1
Pump	984.72	5
Other appliances	150	1
TOTAL	19735.95	100.00%

Image 4.a.: Annual energy consumption chart-Equipment wise (Consumer No. 1145529000140)




Table 4.b. : Annual energy consumption –Equipment wise
(Consumer No. 114523000141)

Loads	Annual Energy Consumption (kWh)	Percentage of energy consumption (%)
T12/ T8 Tube lights	4597	15
CFL/LED lighting	508.64	2
Ventilation (Fan)	13338.6	43
Air conditioner	4224	14
Computer and peripherals	5293.2	17
Other Appliances	2800	9
TOTAL	30761.44	100.00%




Image 4.b. Annual energy consumption chart–Equipment wise
(Consumer No. 114523000141)

5. Energy Saving Potential

An annual energy savings of about 35%, is assessed, by retrofitting inefficient Lights & Fans with Energy Efficient Lights & Fans. Below are the important recommendations and the bar graphs 8.a and 8.b show comparison of existing energy consumption and reduced energy consumption, as per the recommendations for the two consumer numbers, respectively.

1	Replacing the existing T12 Fluorescent Tube lights and T8 Fluorescent Tube lights with 18W LED Tube light.	 LED Tube light
2	Replacing the existing CFL lamps with 7 W LED bulbs .	 LED Bulb
3	Replacing the existing old & inefficient ordinary fans with BEE star rated ceiling fan with service value 4.0 or above. (Energy Saving calculation done considering the power consumption at full speed.)	 BEE star rated fans





Image 5.2 Comparison of energy consumption before and after retrofitting T8 fluorescent tube lights in Consumer No.1145529000140




Image 5.3 Comparison of energy consumption before and after retrofitting CFL Consumer No.1145529000140




Image 5.4 Comparison of energy consumption before and after retrofitting Ceiling fans in Consumer No.1145529000140




Image 5.5 Comparison of energy consumption before and after retrofitting T12 fluorescent tube lights in Consumer No.1145523000141




Image 5.6 Comparison of energy consumption before and after retrofitting T8 fluorescent Tube light in Consumer No.1145523000141




Image 5.5 Comparison of energy consumption before and after retrofitting Ceiling fans in Consumer No.1145523000141




Image 5.5 Comparison of energy consumption before and after retrofitting CFL in Consumer No.1145523000141

6. Recommendations for Energy Saving

Immediate energy savings, can be achieved from the effective usage of lights, Fans and Air Conditioners. The following activities, having no/low investment, can be adopted in these areas.

- Replace the existing Fluorescent Tube lights (T12 & T8), with LED lights, (see the Executive Summary).
- Replace old/ inefficient fans with BEE star rated ceiling fans, with service value 4.0 or above, (see the Executive Summary).
- Switch OFF appliances, when not in use.
- Utilize BEE star labeled appliances, as far as possible.
- Maintain standard Electrical wiring, to avoid energy loss.
- Avoid very old and obsolete appliances and replace with energy efficient and environment friendly appliances.
- The existing Air Conditioners can be replaced with inverter Air conditioners, to get better energy efficiency.
- Avoid the exposure of Air conditioner's outdoor units, to sunlight.
- Avoid air leakage in Air conditioned rooms.
- Keep the computers in sleep/shut down mode, when not in use.(i.e, during lunch time)
- The conventional UPSs in the Central Library Building can be replaced with Modular UPS, which will result in reduction of energy loss, heat loss & operating cost.
- Regular cleaning of glass panes of Windows, light fixtures, Fans and other appliances, to get maximum output.
- Utilize the natural lights and wind, as far as possible, to reduce energy consumption.
- An Energy Conservation cell/club can be constituted and arrange Energy Conservation awareness programmes. Create awareness among the students & employees, about the importance and practice of Energy Conservation and monitor, regularly, the energy conservation activities.

Further, it is recommended to make the Central Library Building, Air conditioned and also, provide Diesel Generator (DG) supply to the Library. This will result in more effective utilization, and smooth & effective functioning of the Library.

7. Details of energy savings calculations

(a). Consumer No.1145529000140, Connected load 36kW

Energy Saving in Lighting by replacing existing 25nos. T12 Fluorescent Tube lights with 18watts LED Tube light.	
Annual working hours(Hrs.)	440
No. of fittings(nos.)	25
Wattage of one light fitting(kW)	0.052
Total load(kW)	1.3
Annual Energy Consumption(kWh)	572
Total Savings of wattage with replacement(kW)	0.85
Annual Energy Saving potential by replacement(kWh)	374
Annual Financial Saving potential (@Rs. 5.7/unit)- Rs.	2132
Investment required, for replacement(@ Rs. 400 per LED Tube light)- Rs.	10000
Pay Back Period in years	4.6

Energy Saving in Lighting by replacing existing 125nos. T8 Fluorescent Tube lights with 18watts LED Tube light.	
Annual working hours(Hrs.)	440
No. of fittings(nos.)	125
Wattage of one light fitting(kW)	0.036
Total load(kW)	4.5
Annual Energy Consumption(kWh)	1980
Total Savings of wattage with replacement(kW)	2.25
Annual Energy Saving potential by replacement(kWh)	990
Annual Financial Saving potential (@Rs. 5.7/unit)- Rs.	5643
Investment required, for replacement(@ Rs. 400 per LED Tube light)- Rs.	50000
Pay Back Period in years	8.8

Energy Saving in Lighting by replacing existing 10nos. CFL Lamp to 7watts LED bulb.	
Annual working hours(Hrs.)	990
No. of fittings(nos.)	10
Wattage of one CFL Lamp(kW)	0.014
Total load(kW)	0.14
Annual Energy Consumption(kWh)	138.6
Total Savings of wattage with replacement(kW)	0.07
Annual Energy Saving potential by replacement(kWh)	69.3
Annual Financial Saving potential (@Rs. 5.7/unit)- Rs.	395
Investment required, for replacement(@ Rs. 160 per LED Bulb)- Rs.	1600
Pay Back Period in years	4

Energy Saving by replacing existing 145nos. inefficient ceiling Fan with BEE star rated ceiling fan (50w), with service value 4.0 or above.	
Annual working hours(Hrs.)	1430
No. of inefficient Fans(nos.)	145
Wattage of one ceiling Fan(kW)	0.075
Total load(kW)	10.875
Annual Energy Consumption(kWh)	15551
Total Savings of wattage with replacement(kW)	3.625
Annual Energy Saving potential by replacement(kWh)	5184
Annual Financial Saving potential (@Rs. 5.7/unit)- Rs.	29549
Investment required, for replacement(@ Rs. 2100 per BEE star rated ceiling Fan)- Rs.	304500
Pay Back Period in years	10

(b). Consumer No.1145523000141, Connected load 10kW

Energy Saving in Lighting by replacing existing 7nos. T12 Fluorescent Tube lights with 18watts LED Tube light.	
Annual working hours(Hrs.)	880
No. of fittings(nos.)	7
Wattage of one light fitting(kW)	0.052
Total load(kW)	0.364
Annual Energy Consumption(kWh)	320
Total Savings of wattage with replacement(kW)	0.238
Annual Energy Saving potential by replacement(kWh)	209
Annual Financial Saving potential (@Rs. 6.5/unit)- Rs.	1359
Investment required, for replacement(@ Rs. 400 per LED Tube light)- Rs.	2800
Pay Back Period in years	2

Energy Saving in Lighting by replacing existing 135nos. T8 Fluorescent Tube lights with 18watts LED Tube light.	
Annual working hours(Hrs.)	880
No. of fittings(nos.)	135
Wattage of one light fitting(kW)	0.036
Total load(kW)	4.86
Annual Energy Consumption(kWh)	4277
Total Savings of wattage with replacement(kW)	2.43
Annual Energy Saving potential by replacement(kWh)	2138
Annual Financial Saving potential (@Rs. 6.5/unit)- Rs.	13897
Investment required, for replacement(@ Rs. 400 per LED Tube light)- Rs.	54000
Pay Back Period in years	3.8

Energy Saving in Lighting by replacing existing 4nos. CFL Lamp to 7watts LED bulb.	
Annual working hours(Hrs.)	880
No. of fittings(nos.)	4
Wattage of one CFL Lamp(kW)	0.014
Total load(kW)	0.056
Annual Energy Consumption(kWh)	49.28
Total Savings of wattage with replacement(kW)	0.028
Annual Energy Saving potential by replacement(kWh)	25
Annual Financial Saving potential (@Rs. 6.5/unit)- Rs.	163
Investment required, for replacement(@ Rs. 160 per LED Bulb)- Rs.	640
Pay Back Period in years	4

Energy Saving by replacing existing 124nos. inefficient ceiling Fan with BEE star rated ceiling fan (50w), with service value 4.0 or above.	
Annual working hours(Hrs.)	1430
No. of inefficient Fans(nos.)	124
Wattage of one ceiling Fan(kW)	0.075
Total load(kW)	9.3
Annual Energy Consumption(kWh)	13299
Total Savings of wattage with replacement(kW)	3.1
Annual Energy Saving potential by replacement(kWh)	4433
Annual Financial Saving potential (@Rs. 6.5/unit)- Rs.	28815
Investment required, for replacement(@ Rs. 2100 per BEE star rated ceiling Fan)- Rs.	260400
Pay Back Period in years	9

8. Annexures

8.1. Annexure 1. Energy Audit Sheets (enclosed)

This document contains data collected during the walk-through audit and survey conducted on 08-02-2020. The number of appliances and hours of usage are indicated, with respect to each room/area in the building.


8.2. Annexure 2. Electricity Bill Details (Bills enclosed)

Consumer No. : 1145529000140
Name of Consumer : Christian College, Kattakkada
Connected Load : 36 kW
Tariff : LT-6A/Three Phase
Name of Section Office : Electrical Section, Kattakkada.

Sl.No	Consumption (Month)	Consumption (kWh)	Monthly Average Consumption (kWh)	Energy Charge (Rs.)
1	July 2020	315	1673	1795.6
2	September 2020	384	1673	2189.27

Consumer No. : 1145523000141
Name of Consumer : Christian College, Kattakkada
Connected Load : 10 kW
Tariff : LT-6A/Three Phase
Name of Section Office : Electrical Section, Kattakkada

Sl.No	Consumption (Month)	Consumption (kWh)	Monthly Average Consumption (kWh)	Energy Charge (Rs.)
1	January 2021	3028	2868	19682.10
2	March 2021	5156	2624	33514.90



Demand/Disconnection Notice
(Electricity Act 2003 P 56)
Customer Care 1912
Kattakada Section
0471-2290242
KSEBL-GSTIN: 32AAECK2277NB21



C# : 1145529000140

KSEB Ltd

KSEB Ltd

Bill# : 4552200800197
Conn. Id : 4872005
Name : THE PRINCIPAL
CHRISTIAN COLLEGEKA
Pole : KD16/3
Trans : OFFICE-1
Meter# : 4901098
Bill Area : MD2/4/16
Bill Date : 01/08/2020
Due Date : 11/08/2020
Disconn Dt : 26/08/2020
Tariff : LT-GR NDom
Purpose : Educational Ins
Deposit : 21294
Meter(MH) Status OK
Load : 36 KW
Demand : 35.32 KVA
Phase : 3
Prv Rd Dt : 01/07/2020
Prs Rd Dt : 01/08/2020
Mt Rd(OMF) : 1

KSEB Ltd

Prv Paid Dt : 29-02-2020
Prv Paid Amt : 12419

Unit	Curr	Prev	Cons	Avg
KWH/R/1	1455	1140	315	1673

Fixed Charges	:	2340.00
Meter Rent	:	17.85
Energy Charges	:	1755.60
Duty	:	179.55

Bill Amount	:	4333.00
Arrears	:	33806.00
Payable	:	38139.00

KSEB Ltd

Remarks
Mtr Rent 15 COST 9% 1 35 GST 9% 1 35
CESS 1% 0.15

Security Deposit
Interest Refund:
Rs 1466
Credited On 29-05-2020

Pay Online <https://www.kseb.in>
SPJIMON K K
Sub Engineer
SIR VI -1 33 /11000214
01-10-2020 16:11:29



Demand/Disconnection Notice
(Electricity Act 2003 P 56)
Customer Care 1912
Kattakada Section
0471-2290242
KSEBL-GSTIN: 32AAECK2277NB21



C# : 1145529000140

Bill# : 4552201000254
Conn. Id : 4872005
Name : THE PRINCIPAL
CHRISTIAN COLLEGEKA
Pole : KD-16/3
Trans : OFFICE-1
Meter# : 4901098
Bill Area : MD2/4/16
Bill Date : 01/10/2020
Due Date : 12/10/2020
Disconn Dt : 27/10/2020
Tariff : LT-GR NDom
Purpose : Educational Ins
Deposit : 21294
Meter(MH) Status OK
Load : 36 KW
Demand : 35.32 KVA
Phase : 3
Prv Rd Dt : 01/09/2020
Prs Rd Dt : 01/10/2020
Mt Rd(OMF) : 1

Prv Paid Dt : 29-02-2020
Prv Paid Amt : 12419

Unit	Curr	Prev	Cons	Avg
KWH/R/1	2123	1729	394	1673

Fixed Charges	:	2340.00
Meter Rent	:	17.85
Energy Charges	:	2185.27
Duty	:	218.88

Bill Amount	:	4706.00
Arrears	:	42276.00
Payable	:	47044.00

KSEB Ltd

Remarks
Mtr Rent 15 COST 9% 1 35 GST 9% 1 35
CESS 1% 0.15

Pay Online <https://www.kseb.in>
SPJIMON K K
Sub Engineer
SIR VI -1 33 /11000214
01-10-2020 16:11:29

KSEB Ltd

Demand/Disconnection Notice
 (Electricity Act 2003 P 56)
 Customer Care 1912
 Kattakada Section
 0471-2290242
 KSEBL-GSTIN: 32AHECK2277NBZ1



C# : 1145523000141

Bill# : 4552210200859
 Conn. Id : 4872006
 Name : PRINCIPAL
 CHRISTIAN COLLEGEKA
 Pole : KD-16/3
 Trans : OFFICE-1
 Meter# : 0010078503
 Bill Area : B04/1/74
 Bill Date : 01/02/2021
 Due Date : 11/02/2021
 Disconn Dt : 26/02/2021
 Tariff : LT-6A NDom
 Purpose : Educational Ins
 Deposit : 46731
 Meter(NK)Status OK
 Load : 10 KW
 Demand : 9.74 KVA
 Phase : 3
 Prv Rd Dt : 01/12/2020
 Prs Rd Dt : 01/02/2021
 Mt Rd(OMF) : 1

101

Prv Paid Dt : 21-01-2021
 Prv Paid Amt : 27676

Unit	Curr	Prev	Cons	Avg
KWH/A/1	153621	150593	3028	2.768

Fixed Charges	: 1300.00
Meter Rent	: 35.70
Energy Charges	: 19682.10
Duty	: 1968.20

Bill Amount : 22986.00
 Surcharge : 427.00
Payable : 23413.00

Remarks
 Mtr Rent: 30 COST 9% 2.7
 CESS 1% 0.3



Demand/Disconnection Notice
 (Electricity Act 2003 P 56)
 Customer Care 1912
 Kattakada Section
 0471-2290242
 KSEBL-GSTIN: 32AHECK2277NBZ1



C# : 1145523000141

Bill# : 4552210400693
 Conn. Id : 4872006
 Name : PRINCIPAL
 CHRISTIAN COLLEGEKA
 Pole : KD-16/3
 Trans : OFFICE-1
 Meter# : 0010078503
 Bill Area : B04/1/74
 Bill Date : 03/04/2021
 Due Date : 13/04/2021
 Disconn Dt : 29/04/2021
 Tariff : LT-6A NDom
 Purpose : Educational Ins
 \$ Deposit : 46731
 Meter(NK)Status OK
 Load : 10 KW
 Demand : 9.74 KVA
 Phase : 3
 Prv Rd Dt : 01/02/2021
 Prs Rd Dt : 03/04/2021
 Mt Rd(OMF) : 1

141

Prv Paid Dt : 05-02-2021
 Prv Paid Amt : 23415

Unit	Curr	Prev	Cons	Avg
KWH/A/1	158777	153621	5156	2624

Fixed Charges	: 1300.00
Meter Rent	: 35.70
Energy Charges	: 33514.90
Duty	: 3351.40

Bill Amount : 38202.00
 Advance : 2.00
Payable : 38200.00

Remarks
 Mtr Rent: 30 COST 9% 2.7
 CESS 1% 0.3

Pay Online <https://wss.ksebl.com>
 MATHEW LOUIS
 Meter Reader
 SSM:VT -1.33 /11000246
 03-04-2021 12:43:51 PM



VYDYUTHI
ENERGY SERVICES

SUSTAINABLE
DEVELOPMENT
GOALS



House No. 3, H Street, Jawahar Nagar, Kowdiar, Thiruvananthapuram, Kerala, India - 695 003.

✉ info@vydyuthi.com ☎ +91 94963 55554 🌐 www.vydyuthi.com